CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1483:100 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410

Contact: Brad Miller (888) 649-9827 Fax (203) 699-3108

DESIGN: Models ANN-4 and ANN-8 remote annunciator switch panels and ANN series annunciator

module Models SAN-CPU, SLU-16R, SLU-16Y, SWU-8, SHO-4, SDR-32, SIN-16, SRU-

8. Refer to listee's data sheet for detailed product description and operational

considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as remote annunciator modules and annunciator switch panels for use with Edwards

> System Technology's separately listed Models IRC-3 (CSFM Listing No. 7165-1591:147 and 7170-1591:157) and FCC (CSFM Listing No. 7165-1591:139 and 7170-1591:158) fire alarm

control units.

XLF: 7120-1591:156

08-15-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 22, 2004 Date Issued: Listing Expires June 30, 2005

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager